| Serial No | - | |
|-----------|---|--|
| | | |



Electroshield - C° OOO





Current Transformer

TLO-10

PASSPORT EK.1.760.000 PS

Manufacturer's address: 24 Sovetskaya str. Babynino, Kaluga region, 249210 Russia Telephone (48448) 2-17-51, fax (48448) 2-24-58 Moscow office: 26 Ryabinovaya Str., building 2, office 307 tel./fax: (495) 660-82-52

1 General Information

Current transformer TLO-10

TU 3414-003-52889537-01

Serial No. _____ Manufacturing date _____

2 Basic Technical Data and Characteristics

| Rated voltage, kV | |
|---|----|
| Maximum operating voltage, kV | |
| Rated primary current, A | |
| Rated secondary current, A | |
| Rated frequency, Hz | |
| Number of secondary windings | |
| Accuracy class: Measuring winding 1И Protection winding 2И | |
| Rated secondary burden, VA Measuring winding 1M Protection winding 2M | |
| Rated instrument security factor of secondary measuring winding FS_{rat} , not more Rated accuracy limit factor of secondary protective winding ALF_{rat} , | |
| not less | |
| Excitation voltage, V: Measuring winding 1M Protection winding 2M | |
| Excitation current, A | |
| Measuring winding 1И Protection winding 2И | |
| Direct-current resistance, mOhm Measuring winding 1 <i>H</i> Protection winding 2 <i>H</i> | |
| Primary winding testing voltage 42 kV 50 Hz 1 min | |
| Secondary windings testing voltage 3 kV 50 Hz 1 min | |
| Insulation level | a_ |
| Climatic class and placement category | |
| Transformer weight, kg (not more) | |
| Partial discharge level, pC | |

ATTENTION! Each overvoltage retesting on the base insulation must be performed in accordance with Electrical Installation Regulations, version 7 chapter 1.8.17 cl. 3.1 table 1.8.16

| | 3 Package Contents |
|---------------------|--------------------|
| Current transformer | 1 pcs |
| Passport | 1 pcs |
| Operation Manual | according to order |

4 Manufacturer's warranties

The manufacturer warrants correct operation of the transformer, provided that the customer follows requirements to operation, mounting, demounting and storage specified in Operation Manual EK.1.760.000 RE.

Warranty service life - 5 years from the transformer commissioning but not more than 5.5 years from the shipment date.

5 Acceptance Certificate

The current transformer conforms to requirements of TU 3414-003-52889537-01 and was qualified for operation

Test responsible signature full name date PT lab stamp The transformer passed the initial verification under Verification Method EK.1.760.000 PM5 Re-verification interval – 8 years Verification officer signature Verification mark full name date impression Acceptance Responsible _ full name QC stamp

signature

date